


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.1312A/2024-25/EE/RDWS&SD/RMG

Dated: 04/09/2024

It is certified that an inspection team headed by T.N. Rangaswamy , Executive Engineer and Mrs. Vidyashree Assistant Engineer from RWS-Division, ZP, Ramanagar inspected the Basaveshwara International Public School, Survey No 170/2 Ittamadu post, Bidadi hobli, Timmegodanadoddi, Ramanagara dist Karnataka 562109 on 04 /09/ 2024 and found that the Basaveshwara International Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 year



To,
The Chairman
Basaveshwar Veershaiva Vidyavardhak
Sangha, Basaveshwara International
Public School, Survey No 170/2
Ittamadu post, Timmegowdanadoddi,
Bidadi hobli, Ramanagara dist,
Karnataka.562109

Executive Engineer
T.N. Rangaswamy and
Sanitation Dept,
Executive Engineer,
Ramanagar Division, Ramanagar,
RWS-Division, Zilla Panchayat,
Ramanagar, Karnataka

T.N. Rangaswamy

CHAIRMAN
B.V V.SANGHA, BAGALKOT

Head Master

Basaveshwara International Public School
Bidadi, Tq-Dist.: Ramanagara-562109



Ramanagara District Water Quality Testing Laboratory

Office of Executive Engineer, Rural Drinking Water & Sanitation Division,

3rd Floor, Zilla Panchayath Bhawan, Ramanagara - 562159, Karnataka.

Email: rdwsd.wqmssp.ramanagarlab@gmail.com

TEST REPORT

Address of the sampling location:

Basaveshwara International Public School,
Ittamadu post, Bidadi hobli,
Ramanagara Taluk & Ramanagar District.
School Dis No: 29320607508

Report date: 02.09.2024

Reference: Sample receipt Form

Sample receipt date: 31.08.2024

Sample code: RNG23O0368-S

Date of Sample collection: 31.08.2024

Analysis start date: 01.09.2024

Analysis completion date: 01.09.2024

Sample collection protocol: APHA Method

Sample Particulars: Drinking Water (Filter Water)

Sample quantity: 1 Litre

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012	Permissible Limit IS 10500 : 2012	Protocol
Description: Colourless liquid.					
1.	pH Value @25 °C	7.67	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Electrical Conductivity, $\mu\text{S}/\text{cm}$ @25 °C	183	–	–	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6): 2018
4.	Colour, Hazen Units	05	5	15	IS 3025 (Part-4) : 2021
5.	Turbidity, NTU	< 0.5	1	5	IS 3025 (Part-10) : 2023
6.	Total Dissolved Solids @ 180°C, mg/l	120	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as CaCO_3 , mg/l	32.16	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO_3 , mg/l	40.44	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	9.71	75	200	IS 3025 (Part-40) : 1991
10.	Magnesium as Mg, mg/l	3.93	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	27.80	250	1000	IS 3025 (Part-32) : 1988
12.	Sulphate as SO_4 , mg/l	1.18	200	400	IS 3025 (Part-24/Sec 1) : 2022
13.	Fluoride as F, mg/l	0.27	1	1.5	APHA 24 rd Edition 4500- F D
14.	Nitrate as NO_3 , mg/l	11.03	45	No relaxation	APHA 24 rd Edition 4500- NO_3 B
15.	Iron as Fe, mg/l	< 0.1	1	No relaxation	IS 3025 (Part-53) : 2003

Remarks: The given sample conforms to the acceptable limits of IS 10500 : 2012 Drinking Water Specification for the above tested parameters only.

Analyzed By

Anil Fadnis
Junior Analyst

RDWSD
Water Quality Lab
Ramanagara.

Authorized Signatory

Deepika
Technical Manager

Note:

RDWSD/WQMSP/TeR/01

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

[Signature]
Head Master

Basaveshwara International Public School
Bidadi, Tq. Dist.: Ramanagara-562109

-:End of Report:-

[Signature]
CHAIRMAN
B.V V.SANGHA, BAGALKOT

Page 1 of 1